EXISTING Ø250 TOILET EXHAUST RISER FROM LEVEL 2 TO REMAIN

EXISTING Ø300 TOILET EXHAUST BRANCH FROM LEVEL 2 AND LEVEL 3 TOILETS TO REMAIN

EXISTING SUPPLY AND EXHAUST AIR DUCTS FROM LEVEL 4 TO LEVEL 2 TO REMAIN

EXISTING TOILET EXHAUST GRILLES TO REMAIN AND BE REBALANCED TO THE AIR QUANTITIES SHOWN

LEVEL-03

LEVEL-04

LEVEL-04 PIPE LAYOUT

AHU PLENUM DETAIL
SCALE 1:50

SS HEATING COIL BOX FOR SA72-CH04
SCALE 1:25

SS HEATING COIL BOX FOR SA72-CH02
SCALE 1:25

SS HEATING COIL BOX FOR SA72-CH03
SCALE 1:25

SS HEATING COIL BOX FOR SA72-CH05
SCALE 1:25

VALVE CONNECTION DETAIL
SCALE: NTS

DISMANTLED VIEW
SCALE: NTS

EQUIPMENT SCHEDULE

LABEL	DESCRIPTION	MAKE	MODEL	DUTY	WATER FLOW RATE	WEIGHT(kg)	ANCIL
SA-72	AIR HANDLING UNIT	COLAIR	2025	2980 L/s		TBC	
ATT-SA72-FX	SILENCER	FANTECH	NTA05C-100-100	2980 L/s		194.6	